

Environmental Protection Agency

§ 141.61

§ 141.54 Maximum residual disinfectant level goals for disinfectants.

MRDLGs for disinfectants are as follows:

Disinfectant residual	MRDLG(mg/L)
Chlorine	4 (as Cl ₂).
Chloramines	4 (as Cl ₂).
Chlorine dioxide	0.8 (as ClO ₂)

[63 FR 69465, Dec. 16, 1998]

§ 141.55 Maximum contaminant level goals for radionuclides.

MCLGs for radionuclides are as indicated in the following table:

Contaminant	MCLG
1. Combined radium-226 and radium-228	Zero.
2. Gross alpha particle activity (excluding radon and uranium).	Zero.
3. Beta particle and photon radioactivity	Zero.
4. Uranium	Zero.

[65 FR 76748, Dec. 7, 2000]

EFFECTIVE DATE NOTE: At 65 FR 76748, Dec. 7, 2000, § 141.55 was added, effective Dec. 8, 2003.

Subpart G—National Revised Primary Drinking Water Regulations: Maximum Contaminant Levels and Maximum Residual Disinfectant Levels

EFFECTIVE DATE NOTE: At 65 FR 76748, Dec. 7, 2000, the heading of subpart G was revised to read "National Primary Drinking Water Regulations: Maximum Contaminant Levels

and Maximum Residual Disinfectant Levels", effective Dec. 8, 2003.

§ 141.60 Effective dates.

(a) The effective dates for § 141.61 are as follows:

(1) The effective date for paragraphs (a)(1) through (a)(8) of § 141.61 is January 9, 1989.

(2) The effective date for paragraphs (a)(9) through (a)(18) and (c)(1) through (c)(18) of § 141.61 is July 30, 1992.

(3) The effective date for paragraphs (a)(19) through (a)(21), (c)(19) through (c)(25), and (c)(27) through (c)(33) of § 141.61 is January 17, 1994. The effective date of § 141.61(c)(26) is August 17, 1992.

(b) The effective dates for § 141.62 are as follows:

(1) The effective date of paragraph (b)(1) of § 141.62 is October 2, 1987.

(2) The effective date for paragraphs (b)(2) and (b)(4) through (b)(10) of § 141.62 is July 30, 1992.

(3) The effective date for paragraphs (b)(11) through (b)(15) of § 141.62 is January 17, 1994.

(4) The effective date for § 141.62(b)(16) is January 23, 2006.

[56 FR 3593, Jan. 30, 1991, as amended at 57 FR 31846, July 17, 1992; 59 FR 34324, July 1, 1994; 66FR 7063, Jan. 22, 2001]

§ 141.61 Maximum contaminant levels for organic contaminants.

(a) The following maximum contaminant levels for organic contaminants apply to community and non-transient, non-community water systems.

CAS No.	Contaminant	MCL (mg/l)
(1) 75-01-4	Vinyl chloride	0.002
(2) 71-43-2	Benzene	0.005
(3) 56-23-5	Carbon tetrachloride	0.005
(4) 107-06-2	1,2-Dichloroethane	0.005
(5) 79-01-6	Trichloroethylene	0.005
(6) 106-46-7	para-Dichlorobenzene	0.075
(7) 75-35-4	1,1-Dichloroethylene	0.007
(8) 71-55-6	1,1,1-Trichloroethane	0.2
(9) 156-59-2	cis-1,2-Dichloroethylene	0.07
(10) 78-87-5	1,2-Dichloropropane	0.005
(11) 100-41-4	Ethylbenzene	0.7
(12) 108-90-7	Monochlorobenzene	0.1
(13) 95-50-1	o-Dichlorobenzene	0.6
(14) 100-42-5	Styrene	0.1
(15) 127-18-4	Tetrachloroethylene	0.005
(16) 108-88-3	Toluene	1
(17) 156-60-5	trans-1,2-Dichloroethylene	0.1
(18) 1330-20-7	Xylenes (total)	10
(19) 75-09-2	Dichloromethane	0.005
(20) 120-82-1	1,2,4-Trichloro- benzene07
(21) 79-00-5	1,1,2-Trichloro- ethane005

§ 141.61**40 CFR Ch. I (7-1-03 Edition)**

(b) The Administrator, pursuant to section 1412 of the Act, hereby identifies as indicated in the Table below granular activated carbon (GAC), packed tower aeration (PTA), or oxidation (OX) as the best technology treat-

ment technique, or other means available for achieving compliance with the maximum contaminant level for organic contaminants identified in paragraphs (a) and (c) of this section:

BAT FOR ORGANIC CONTAMINANTS LISTED IN § 141.61 (a) AND (c)

CAS No.	Contaminant	GAC	PTA	OX
15972-60-8	Alachlor	X
116-06-3	Aldicarb	X
1646-88-4	Aldicarb sulfone	X
1646-87-3	Aldicarb sulfoxide	X
1912-24-9	Atrazine	X
71-43-2	Benzene	X	X
50-32-8	Benz[a]pyrene	X
1563-66-2	Carbofuran	X
56-23-5	Carbon tetrachloride	X	X
57-74-9	Chlordane	X
75-99-0	Dalapon	X
94-75-7	2,4-D	X
103-23-1	Di (2-ethylhexyl) adipate	X	X
117-81-7	Di (2-ethylhexyl) phthalate	X
96-12-8	Dibromochloropropane (DBCP)	X	X
95-50-1	o-Dichlorobenzene	X	X
106-46-7	para-Dichlorobenzene	X	X
107-06-2	1,2-Dichloroethane	X	X
75-35-4	1,1-Dichloroethylene	X	X
156-59-2	cis-1,2-Dichloroethylene	X	X
156-60-5	trans-1,2-Dichloroethylene	X	X
75-09-2	Dichloromethane	X
78-87-5	1,2-Dichloropropane	X	X
88-85-7	Dinoseb	X
85-00-7	Diquat	X
145-73-3	Endothall	X
72-20-8	Endrin	X
100-41-4	Ethylbenzene	X	X
106-93-4	Ethylene Dibromide (EDB)	X	X
1071-83-6	Glyphosate	X
76-44-8	Heptachlor	X
1024-57-3	Heptachlor epoxide	X
118-74-1	Hexachlorobenzene	X
77-47-3	Hexachlorocyclopentadiene	X	X
58-89-9	Lindane	X
72-43-5	Methoxychlor	X
108-90-7	Monochlorobenzene	X	X
23135-22-0	Oxamyl (Vydate)	X
87-86-5	Pentachlorophenol	X
1918-02-1	Picloram	X
1336-36-3	Polychlorinated biphenyls (PCB)	X
122-34-9	Simazine	X
100-42-5	Styrene	X	X
1746-01-6	2,3,7,8-TCDD (Dioxin)	X
127-18-4	Tetrachloroethylene	X	X
108-88-3	Toluene	X	X
8001-35-2	Toxaphene	X
93-72-1	2,4,5-TP (Silvex)	X
120-82-1	1,2,4-Trichlorobenzene	X	X
71-55-6	1,1,1-Trichloroethane	X	X
79-00-5	1,1,2-Trichloroethane	X	X
79-01-6	Trichloroethylene	X	X
75-01-4	Vinyl chloride	X
1330-20-7	Xylene	X	X

(c) The following maximum contaminant levels for synthetic organic contaminants apply to community water

systems and non-transient, non-community water systems:

Environmental Protection Agency
§ 141.62

CAS No.	Contaminant	MCL (mg/l)
(1) 15972-60-8	Aalachlor	0.002
(2) 116-06-3	Aldicarb	0.003
(3) 1646-87-3	Aldicarb sulfoxide	0.004
(4) 1646-87-4	Aldicarb sulfone	0.002
(5) 1912-24-9	Atrazine	0.003
(6) 1563-66-2	Carbofuran	0.04
(7) 57-74-9	Chlordane	0.002
(8) 96-12-8	Dibromochloropropane	0.0002
(9) 94-75-7	2,4-D	0.07
(10) 106-93-4	Ethylene dibromide	0.00005
(11) 76-44-8	Heptachlor	0.0004
(12) 1024-57-3	Heptachlor epoxide	0.0002
(13) 58-89-9	Lindane	0.0002
(14) 72-43-5	Methoxychlor	0.04
(15) 1336-36-3	Polychlorinated biphenyls	0.0005
(16) 87-86-5	Pentachlorophenol	0.001
(17) 8001-35-2	Toxaphene	0.003
(18) 93-72-1	2,4,5-TP	0.05
(19) 50-32-8	Benz[a]pyrene	0.0002
(20) 75-99-0	Dalapon	0.2
(21) 103-23-1	Di(2-ethylhexyl) adipate	0.4
(22) 117-81-7	Di(2-ethylhexyl) phthalate	0.006
(23) 88-85-7	Dinoseb	0.007
(24) 85-00-7	Diquat	0.02
(25) 145-73-3	Endothall	0.1
(26) 72-20-8	Endrin	0.002
(27) 1071-53-6	Glyphosate	0.7
(28) 118-74-1	Hexachlorobenzene	0.001
(29) 77-47-4	Hexachlorocyclopentadiene	0.05
(30) 23135-22-0	Oxamyl (Vydate)	0.2
(31) 1918-02-1	Picloram	0.5
(32) 122-34-9	Simazine	0.004
(33) 1746-01-6	2,3,7,8-TCDD (Dioxin)	3×10^{-8}

[56 FR 3593, Jan. 30, 1991, as amended at 56 FR 30280, July 1, 1991; 57 FR 31846, July 17, 1992; 59 FR 34324, July 1, 1994]

§ 141.62 Maximum contaminant levels for inorganic contaminants.

(a) [Reserved]

(b) The maximum contaminant levels for inorganic contaminants specified in paragraphs (b) (2)-(6), (b)(10), and (b) (11)-(16) of this section apply to community water systems and non-transient, non-community water systems. The maximum contaminant level specified in paragraph (b)(1) of this section only applies to community water systems. The maximum contaminant levels specified in (b)(7), (b)(8), and (b)(9) of this section apply to community water systems; non-transient, non-community water systems; and transient non-community water systems.

Contaminant	MCL (mg/l)
(8) Nitrite	1 (as Nitrogen)
(9) Total Nitrate and Nitrite	10 (as Nitrogen)
(10) Selenium	0.05
(11) Antimony	0.006
(12) Beryllium	0.004
(13) Cyanide (as free Cyanide).	0.2
(14) [Reserved]	
(15) Thallium	0.002
(16) Arsenic	0.010

(c) The Administrator, pursuant to section 1412 of the Act, hereby identifies the following as the best technology, treatment technique, or other means available for achieving compliance with the maximum contaminant levels for inorganic contaminants identified in paragraph (b) of this section, except fluoride:

BAT FOR INORGANIC COMPOUNDS LISTED IN SECTION 141.62(B)

Contaminant	MCL (mg/l)
(1) Fluoride	4.0
(2) Asbestos	7 Million Fibers/liter (longer than 10 μm).
(3) Barium	2
(4) Cadmium	0.005
(5) Chromium	0.1
(6) Mercury	0.002
(7) Nitrate	10 (as Nitrogen)

Chemical Name	BAT(s)
Antimony	2.7
Arsenic ⁴	1, 2, 5, 6, 7, 9, 12 ⁵